



Emissionsmessung Bioenergiedorf Möggingen

Biogas-BHKW-Modul 250 kW_{el}; 360 kW_{th}; 663 kW_{Brennstoffleist.}

Messkomponente	Kohlenmonoxid (CO)	NO _x als NO	Formaldehyd (HCHO)	Stromeinspeisung	Anteil BHKW an Wärmeversorgung	Vollbenutzungsstunden
Grenzwert BImSchG	1000	500	40			
Einheit	mg/m³	mg/m³	mg/m³	kWh_{el}	kWh_{th}	h p.a.
2011	420	460	37,9	1.354.686	1.459.400 (46,7%)	5.838
2012	70	420	13	2.075.828	2.380.200 (67,2%)	8.303
2013	240	460	26,3	2.064.973	2.363.164 (62,6%)	8.259
2014	220	460	32,6	2.087.773	2.312.700 (70,2%)	8.351
2015	100	410	9	1.972.336	2.235.500 (58,8%)	7.889